

September 23, 2004

SCALTROL INCORPORATED
6350 REGENCY PKWY
NORCROSS GA 30071

Re: Description: WATER TREATMENT CHEMICAL INJECTION DEVICE
Manufacturer: SCALTROL INCORPORATED
Product Name: SCALTROL
Model Number(s): SC-50 (USING THE RSC-50 CARTRIDGE) AND
SC-100 (USING THE RSC-100 CARTRIDGE)
Product File No: 20040297

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2009.

This approval supercedes the approval issued on May 4, 1999 under product file number 19980595.

This approval is contingent upon compliance with the following stipulation(s):

- Only CalciQuest-Dry ST blended polyphosphate, listed under NSF International Standard 60, can be used with this product.
- The maximum concentration of CalciQuest-Dry ST in the treated water downstream of these devices must not exceed 10.0 mg/L.
- These products have undergone sufficient testing to document their ability to properly inject a chemical into a water supply system as specified in this approval letter.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product to inject a chemical into a water supply system. For more information contact the DNR Private Water Systems Section, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.

These devices were tested under controlled laboratory, or field, conditions. The actual performance of these devices for a specific end use installations will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry. The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
gschlueter@commerce.state.wi.us **Email**
GWS:gws
SBD-10564-E (N.10/97)